

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 972 / D / SWA / NSA

Dated: 06/02/2024

It is certified that an inspection team headed by Mrs. ALKA SINGH - CHEMIST (HEALTH)
(Name of Officers with designation) from KANPUR NAGAR NIGAM
(Name of Department/ Office) inspected the Dr. Viswendra Swarnup Education Centre, Panki
(Name & Address of the school) on 30/01/2024 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year.

Signature with Seal:

Name

Dr. Ajay Kumar

Designation :

N.S.A.

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

Dr. Viswendra Swarnup Education Centre
804-A, 'B' Block, Panki, Kanpur Nagar

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the Dr. VIRENDRA SWARUP EDUCATION CENTRE
804 A - B, Block Panki
Kanpur

Sample taken from	Submersible
Date of sample Drawn	30/1/2024
Date of analysis	30/1/2024
Physical Character	Transparent
P. H. Value	7.06
Free Ammonia Parts per 1000000	NIL
Albuminoid Ammonia Part per 1000000	NIL
Oxygen absorbed from pot. Permagnate in three hours at 37° C	0.0
Chloride Part per 1000000	24.00
Nitrates Parts per 1000000	NIL
Nitrates Parts per 1000000	NIL
Total solid part per 100000	460.00
Fixed solid Parts per 1000000	390.00
Volatils solid Parts per 100000	70.00
Appearance on ignition	No Charring
Total hardness Parts per 1000000	260.00
Permanent hardness Parts per 1000000	196.00
Temporary hardness Parts per 1000000	64.00

K.N.N. PRESS

Remarks : 'POTABLE'

No. 330/swapn dated 06/02/2024

Copy forwarded for fovour or information to

Dr. Virendra Swarup Education Centre
804 A, B-Block, Panki Kanpur

Nagar Swasthya Adhikari
Nagar Nigam Kanpur
ALKA SINGH नगर स्वास्थ्य अधिकारी
(Chemist) नगर निगम कानपुर
Nagar Nigam Kanpur

D.No. 330/SWA/chem 06/02/2024



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from Dr. Vinendra Swamy Education Centre 884-A,
Name & designation of the person collecting samples... ALKA SINGH - CHEMIST B' Block, Panki, Kanpur

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count			Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37.c in 48 hours	at room temp- return in 72 hours	Quantity of water put in each tube No of tubes put up	50ML. 1	10 ML. 5			

01/01/2024 Submersible ZERO 16 — — NIL NIL NIL ZERO NIL NIL (Satisfactory)

Copy for Information Forwarded to (1) Dr. Vinendra Swamy Education Centre, Panki, Kanpur
(2) N.S.A. Kanpur Nagar Nigam

Atk. Nagar Swasthya Adhikari
ALKA SINGH
(Chemist) नगर निगम कानपुर
Nagar Nigam Kanpur